

DECLARATION OF PERFORMANCE

No. 921513600_59_001

1. Unique identification code of the product-type: **BSR-5136**
2. Intended use/es: Addressable manual call point for use in fire detection and alarm systems for buildings.
3. Manufacturer: Olympia Electronics N. Lakasas – P. Arvanitidis S.A., 72ns klm Old national road Thessaloniki-Katerini, Eginio, Pieria, Greece, P.O. 60300
4. System/s AVCP: System 1
5. Harmonized standard: EN 54-11:2001 +A1:2005 - Fire detection and fire alarm systems - Part 11: Manual call points

EN 54-17:2005 /AC:2007 Fire detection and fire alarm systems - Part 17: Short-circuit isolators

Notified body/ies: EVPU AS, No. 1293


6. Declared performance/s:

Essential characteristics	Performance	Harmonised technical specification	
		EN 54-11:2001 EN 54-1:2001 /A1:2005	EN 54-17:2005 EN 54-17:2005 /AC:2007
Nominal activation conditions / Sensitivity and Performance under fire conditions	PASS	4.3.2, 4.4, 4.7.1, 4.7.4=N/A, 5.2, 5.3	5.2
Operational reliability	PASS	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	4
Durability of operational reliability: temperature resistance	PASS	5.7, 5.8=N/A, 5.9	5.4, 5.5
Durability of operational reliability: vibration resistance	PASS	5.14 to 5.17	5.9 to 5.12
Durability of operational reliability: humidity resistance	PASS	5.10, 5.11=N/A, 5.12, 5.19=N/A	5.6, 5.7
Durability of operational reliability: corrosion resistance	PASS	5.11=N/A, 5.13	5.8
Durability of operational reliability: electrical stability	PASS	5.6, 5.18	5.3, 5.13

Comments:

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of:



Elias Tsologiannis, R&D engineer

Eginio, Pieria, Greece 10/2/2020