



Ref. Certif. No.

GB942W/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

Emergency Luminaires

Name and address of the applicant
Nom et adresse du demandeur

Olympia Electronics N. Lakasas – P. Arvanitidis S.A.
72nd klm Old National Road
Thessaloniki – Katerini, Aiginio, Pieria
60300, Greece

Name and address of the manufacturer
Nom et adresse du fabricant

As above

Name and address of the factory
Nom et adresse de l'usine

As above

Note: When more than one factory, please report on page 2
Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Input 220-240V AC 50-60 Hz
Class II

Trademark (if any)
Marque de fabrique (si elle existe)

Olympia Electronics S.A.

Model / Type Ref.
Ref. De type

See pages 2 & 3

Additional information (if necessary may also be reported
on page 2)

Including European Group differences

Les informations complémentaires (si nécessaire,, peuvent
être indiqués sur la 2^{ème} page

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

As shown in the Test Report Ref. No. which forms part of
this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

PUBLICATION

EDITION

IEC 60598-1:2014
IEC 60598-2-22:2014

8 th
4 th

New report number: 3058617
Original report number: 8408547

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 14 August 2019

Signature:

Holly Rossington – Electrical Certification Team Leader



Ref. Certif. No.

GB942W/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

The type references covered by this certificate are as listed below:

The Emergency Luminaires are Class II, Self contained, Maintained or Non-Maintained, Wall or Ceiling mounted

Model	Power	IP rating	Number of LEDs	Addressable function
GR-1315/15L	3.4W/3.8VA	40	15	No
GR-1315/30L	4.5W/4.9VA	40	30	No
GR-1316/15L	3.3W/3.7VA	40	15	No
GR-1316/30L	5.3W/5.6VA	40	30	No
GR-1315/15L/ADR	3.4W/3.8VA	40	15	Yes
GR-1315/30L/ADR	4.5W/4.9VA	40	30	Yes
GR-1316/15L/ADR	3.3W/3.7VA	40	15	Yes
GR-1316/30L/ADR	5.3W/5.6VA	40	30	Yes
GR-1938/15L	3.4W/3.8VA	65	15	No
GR-1938/30L	4.5W/4.9VA	65	30	No
GR-1939/15L	3.3W/3.7VA	65	15	No
GR-1939/30L	5.3W/5.6VA	65	30	No
GR-1938/15L/ADR	3.4W/3.8VA	65	15	No
GR-1938/30L/ADR	4.5W/4.9VA	65	30	Yes
GR-1939/15L/ADR	3.3W/3.7VA	65	15	Yes
GR-1939/30L/ADR	5.3W/5.6VA	65	30	Yes
GR-938/15L/ADR	3.4W/3.8VA	65	15	Yes
GR-938/30L/ADR	4.5W/4.9VA	65	30	Yes
GR-939/15L/ADR	3.3W/3.7VA	65	15	Yes
GR-939/30L/ADR	5.3W/5.6VA	65	30	Yes
GR-938/15L	3.4W/3.8VA	65	15	No
GR-938/30L	4.5W/4.9VA	65	30	No

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 14 August 2019

Signature:

Holly Rossington – Electrical Certification Team Leader



Ref. Certif. No.

GB942W/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

The type references covered by this certificate are as listed below:

The Emergency Luminaires are Class II, Self contained, Maintained or Non-Maintained, Wall or Ceiling mounted

Model	Power	IP rating	Number of LEDs	Addressable function
GR-939/15L	3.3W/3.7VA	65	15	No
GR-939/30L	5.3W/5.6VA	65	30	No
GR-315/15L/ADR/A	3.4W/3.8VA	40	15	Yes
GR-315/30L/ADR/A	4.5W/4.9VA	40	30	Yes
GR-316/15L/ADR/A	3.3W/3.7VA	40	15	Yes
GR-316/30L/ADR/A	5.3W/5.6VA	40	30	Yes
GR-315/15L/A	3.4W/3.8VA	40	15	No
GR-315/30L/A	4.5W/4.9VA	40	30	No
GR-316/15L/A	3.3W/3.7VA	40	15	No
GR-316/30L/A	5.3W/5.6VA	40	30	No

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

bsi.

BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 14 August 2019

Signature:

Holly Rossington – Electrical Certification Team Leader