

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST SCHEME

CB TEST CERTIFICATE

Product

Emergency Luminaires

Name and address of the applicant

Olympia Electronics N. Lakasas – P. Arvanitidis S.A.
72nd klm Old National Road
Thessaloniki – Katerini, Aiginio, Pieria
60300, Greece

Name and address of the manufacturer

As above

Name and address of the factory

As above

Note: When more than one factory, please
report on page 2

Ratings and principal characteristics

Input 220-240V AC 50-60 Hz
Class II, IP65

Trademark (if any)

Olympia Electronics S.A.

Model / Type Refs.

See page 2

Additional information (if necessary may also be
reported on page 2)

N/A

A sample of the product was tested and found
to be in conformity with

Publication

IEC 60598-1:2015
IEC 60598-2-22:2014

As shown in the Test Report Ref. No. which
forms part of this Certificate


Report number: 9787475

This CB Test Certificate is issued by the National Certification Body



BSI, Kitemark Court
Davy Avenue, Knowlhill
Milton Keynes, MK5 8PP
United Kingdom.
Phone +44 (0)8450 809000
Signature:

Date: 12 February 2020



Holly Rossington Certification manager

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST SCHEME

The type references covered by this certificate are as listed below:

Model	Rating	Duration	IP	Assembly type
SLL-501/WP	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency exit luminaire
SLL-503/WP	220-240 V Class II 50/60Hz	3 hours	IP65	Surface mounted emergency exit luminaire
SLL-1001/WP	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency exit luminaire
SLL-1003/WP	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency exit luminaire
SLL-1011/WP	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency luminaire
SLL-1013/WP	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency luminaire
SLL-1021/WP	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency luminaire
SLL-1023/WP	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency luminaire
SLL-501/WP/ADR	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency exit luminaire
SLL-503/WP/ADR	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency exit luminaire

This CB Test Certificate is issued by the National Certification Body



BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Signature:



Holly Rossington Certification Manager

Date: 12 February 2020

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST SCHEME

The type references covered by this certificate are as listed below:

SLL-1001/WP/ADR	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency exit luminaire
SLL-1003/WP/ADR	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency exit luminaire
SLL-1011/WP/ADR	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency luminaire
SLL-1013/WP/ADR	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency luminaire
SLL-1021/WP/ADR	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency luminaire
SLL-1023/WP/ADR	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency luminaire

This CB Test Certificate is issued by the National Certification Body



Date: 12 February 2020

BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Signature:



Holly Rossington Certification Manager