



ACCREDITED BY ESYD FOR CERTIFICATION (125-3).
NOTIFIED BODY (0848) FOR THE 2006/95/EC, 2009/142/EC DIR & 305/2011/EU REG.
103 KEFALLHNIAS STR, 112 51 ATHENS – GREECE
TEL.: +30-210-8670588 – FAX: +30-210-8647510
e-mail: info@heeqac.gr, site: www.heeqac.gr

CERTIFICATION
CERT.No. 125-3

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Nr:

0848-CPR-009

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

DATE OF ISSUE	: APRIL 15, 2015
ISSUED TO	: NIKOLAOS LAKASAS AND PANAGIOTIS ARVANITIDIS S.A., 72 KLM OLD NATIONAL ROAD THESSALONIKIS - KATERINIS, 600 61, KOLINDROS, PIERIA, GREECE
PRODUCT TYPE	: FIRE ALARM ADDRESSABLE RATE OF RISE HEAT DETECTOR
TRADE MARK/MODELS	: OLYMPIA ELECTRONICS/ BSR-6060/A
MANUFACTURER	: NIKOLAOS LAKASAS AND PANAGIOTIS ARVANITIDIS S.A., 72 KLM OLD NATIONAL ROAD THESSALONIKIS - KATERINIS, 600 61, KOLINDROS, PIERIA, GREECE
APPLICABLE STANDARDS	: EN 54-5:2001 +A1:2002

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the above mentioned standard(s) under system 1 are applied and that the product fulfills all the prescribed requirements set out above.

COMMENTS:

This certificate was first issued on 15 April 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



G. CHRYSANTHAKOPOULOS
GENERAL MANAGER

HEEQAC S.A.
HELLENIC ELECTRONICS EQUIPMENT
QUALITY ASSURANCE CENTRE
103 KEFALLHNIAS STR, 112 51 ATHENS, GREECE
TEL.: +30210 8670588 – FAX: +30210 8647510
VAT NO. EL004253599 – TAX AUTH. ATHENS 9497
Email: info@heeqac.gr

ATHENS, APRIL 15, 2015