

Kitemark™ Certificate

This is to certify that:

Olympia Electronics
N. Lakasas - P. Arvanitidis S.A.
72nd klm Old National Road
Thessaloniki - Katerini
Kolindros, Pieria
60300
Greece

Holds Certificate Number:

KM 640081


In respect of:

BS EN 60598-2-22
Emergency luminaires

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:



Chris Lewis - Certification Director, Product Certification

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17



Page: 1 of 11

...making excellence a habit.™

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

GR range of emergency luminaires

Rated 220-240V AC/50-60Hz Class II

BSI Test Report reference 8408551.

| Model | Light source | Mode | Duration | Assembly type |
|--------------|--------------|---------------------------|-----------|---|
| GR-310/30L/A | LED | Non-Maintained/Maintained | 1.5 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-312/30L/A | LED | Non-Maintained/Maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-310/15L/A | LED | Non-Maintained/Maintained | 1.5 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-312/15L/A | LED | Non-Maintained/Maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-312/LS/A | LED | Non-Maintained/Maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-1936/30L | LED | Non-Maintained/Maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1936/15L | LED | Non-Maintained/Maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1935/30L | LED | Non-Maintained/Maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1935/15L | LED | Non-Maintained/Maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1310/30L | LED | Non-Maintained/Maintained | 1.5 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-1310/15L | LED | Non-Maintained/Maintained | 1.5 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-1312/30L | LED | Non-Maintained/Maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-1312/15L | LED | Non-Maintained/Maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 2 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

GR range of emergency luminaires

Rated 220-240V AC/50-60Hz Class II

BSI Test Report reference 8408547

| Model | Light source | Mode | Duration | Assembly type |
|------------------|--------------|-------------------------------------|-----------|---|
| GR-315/15L/ADR/A | LED | Addressable self-testing maintained | 1.5 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-315/15L/A | LED | Self-testing maintained | 1.5 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-316/15L/ADR/A | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-316/15L/A | LED | Self-testing maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-315/30L/ADR/A | LED | Addressable self-testing maintained | 1.5 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-315/30L/A | LED | Self-testing maintained | 1.5 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-316/30L/ADR/A | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-316/30L/A | LED | Self-testing maintained | 3 hours | Ceiling/Wall/Suspension mounted. Emergency/exit luminaire. IP40 |
| GR-938/15L/ADR | LED | Addressable self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-938/15L | LED | Self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-938/30L/ADR | LED | Addressable self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-938/30L | LED | Self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-939/15L/ADR | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-939/15L | LED | Self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 3 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

GR range of emergency luminaires (continued)

| Model | Light source | Mode | Duration | Assembly type |
|-----------------|--------------|-------------------------------------|-----------|---|
| GR-939/30L/ADR | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-939/30L | LED | Self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1939/30L/ADR | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1939/30L | LED | Self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1939/15L/ADR | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1939/15L | LED | Self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1938/30L/ADR | LED | Addressable self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1938/30L | LED | Self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1938/15L/ADR | LED | Addressable self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1938/15L | LED | Self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP65 |
| GR-1316/30L/ADR | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP40 |
| GR-1316/30L | LED | Self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP40 |
| GR-1316/15L/ADR | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP40 |
| GR-1316/15L | LED | Self-testing maintained | 3 hours | Ceiling/Wall mounted. Emergency luminaire. IP40 |
| GR-1315/30L/ADR | LED | Addressable self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP40 |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 4 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

GR range of emergency luminaires (continued)

| Model | Light source | Mode | Duration | Assembly type |
|-----------------|--------------|-------------------------------------|-----------|---|
| GR-1315/30L | LED | Self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP40 |
| GR-1315/15L/ADR | LED | Addressable self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP40 |
| GR-1315/15L | LED | Self-testing maintained | 1.5 hours | Ceiling/Wall mounted. Emergency luminaire. IP40 |

GR range of emergency luminaires

Rated 220-240V AC/50-60Hz Class II

BSI Test Report reference 8408552-1 Rev 2

| Model | Light source | Mode | Duration | Assembly type |
|------------|--------------|---|-----------|--|
| GR-290/ADR | LED | Addressable, Self testing, non maintained | 1.5 hours | Ceiling/Wall/recess mounted. Emergency luminaire. IP40 |
| GR-291/ADR | LED | Addressable, Self testing, non maintained | 1.5 hours | Ceiling/Wall/recess mounted. Emergency luminaire. IP40 |
| GR-292/ADR | LED | Addressable, Self testing, non maintained | 3 hours | Ceiling/Wall/recess mounted. Emergency luminaire. IP40 |
| GR-293/ADR | LED | Addressable, Self testing, non maintained | 3 hours | Ceiling/Wall/recess mounted. Emergency luminaire. IP40 |
| GR-290 | LED | Self testing non maintained | 1.5 hours | Ceiling/Wall/recess mounted. Emergency luminaire. IP40 |
| GR-291 | LED | Self testing non maintained | 1.5 hours | Ceiling/Wall/recess mounted. Emergency luminaire. IP40 |
| GR-292 | LED | Self testing non maintained | 3 hours | Ceiling/Wall/recess mounted. Emergency luminaire. IP40 |
| GR-293 | LED | Self testing non maintained | 3 hours | Ceiling/Wall/recess mounted. Emergency luminaire. IP40 |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 5 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

MLD range of emergency luminaires

Rated 220-240V AC/50-60Hz Class II IP40

BSI Test Report reference 8413436.

| Model | Light source | Mode | Duration | Assembly type |
|-----------|--------------|----------------|----------|---|
| MLD-28D/w | LED | Self-contained | 3 hours | Ceiling/Wall/Suspension mounted. Exit sign. |
| MLD-34D/w | LED | Self-contained | 3 hours | Ceiling/Wall/Suspension mounted. Exit sign. |
| MLD-44D/w | LED | Self-contained | 3 hours | Ceiling/Wall/Suspension mounted. Exit sign. |

ZLD range of emergency luminaires

Rated 220-240V AC/50-60Hz Class I IP40

BSI Test Report reference 8408549.

| Model | Light source | Mode | Duration | Assembly type |
|---------------|--------------|-------------------------------------|----------|----------------------------------|
| ZLD-28/EM/ADR | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall mounted. Exit sign. |
| ZLD-28/EM | LED | Self-testing maintained | 3 hours | Ceiling/Wall mounted. Exit sign |
| ZLD-34/EM/ADR | LED | Addressable self-testing maintained | 3 hours | Ceiling/Wall mounted. Exit sign |
| ZLD-34/EM | LED | Self-testing maintained | 3 hours | Ceiling/Wall mounted. Exit sign |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 6 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

GR range of emergency luminaires for central battery system

Rated 15-30V, Class III

BSI Test Report reference 8607093 Rev 1

| Model | Rating (DC) | IP | No of LEDs | Assembly type | Dimensions (mm) |
|----------------------|------------------|----|------------|----------------------|-----------------|
| GR-324/15L/24VDC/A | 15-30 V 1W | 40 | 15 | Ceiling/Wall mounted | 353 x 143 x 57 |
| GR-324/30L/24VDC/A | 15-30 V 2W | 40 | 30 | Ceiling/Wall mounted | 353 x 143 x 57 |
| GR-324/15L/24V/ADR/A | 15-30 V 1.5W | 40 | 15 | Ceiling/Wall mounted | 353 x 143 x 57 |
| GR-324/30L/24V/ADR/A | 15-30 V 2.3W | 40 | 30 | Ceiling/Wall mounted | 353 x 143 x 57 |
| GR-1324/15L/24VDC | 15-30 V 1W | 40 | 15 | Ceiling/Wall mounted | 353 x 143 x 57 |
| GR-1324/30L/24VDC | 15-30 V 2W | 40 | 30 | Ceiling/Wall mounted | 353 x 143 x 57 |
| GR-1926/15L/24VDC | 15-30 V 1W | 65 | 15 | Ceiling/Wall mounted | 313 x 118 x 66 |
| GR-1926/30L/24VDC | 15-30 V 2W | 65 | 30 | Ceiling/Wall mounted | 313 x 118 x 66 |
| GR-1325/15L/24V/ADR | 15-30 V 1.5W | 40 | 15 | Ceiling/Wall mounted | 353 x 143 x 57 |
| GR-1325/30L/24V/ADR | 15-30 V 2.3W | 40 | 30 | Ceiling/Wall mounted | 353 x 143 x 57 |
| GR-1926/15L/24V/ADR | 15-30 V 1.5W | 65 | 15 | Ceiling/Wall mounted | 313 x 118 x 66 |
| GR-1926/30L/24V/ADR | 15-30 V 2.3 W | 65 | 30 | Ceiling/Wall mounted | 313 x 118 x 66 |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 7 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

GR range of Emergency exit sign luminaires for central battery system

Rated 85-250VDC/100-250V~50-60Hz Cl.II

BSI Test Report reference 8439708 Rev 1

| Model | Rating | IP | No of LEDs | Assembly type | Dimensions (mm) |
|--------------|--|----|------------|---|-----------------|
| GR-1926/30L | 85-250 VDC 100-250 VAC 50-60 Hz 2.8 W / 3.1 VA | 65 | 30 | Ceiling/wall mounted emergency exit sign | 313x118x66 |
| GR-1926/15L | 85-250 VDC 100-250 VAC 50-60 Hz 1.5 W / 1.9 VA | 65 | 15 | Ceiling/wall mounted emergency exit sign | 313x118x66 |
| GR-1324/30L | 85-250 VDC 100-250 VAC 50-60 Hz 2.8 W / 3.1 VA | 40 | 30 | Ceiling/wall mounted emergency exit sign | 353x143x60 |
| GR-1324/15L | 85-250 VDC 100-250 VAC 50-60 Hz 1.5 W / 1.9 VA | 40 | 15 | Ceiling/wall mounted emergency exit sign | 353x143x60 |
| GR-324/15L/A | 85-250V DC 100-250V AC / 50-60Hz 1.5 W / 1.9 VA | 40 | 15 | Ceiling/wall mounted emergency exit sign | 353x143x57 |
| GR-324/30L/A | 85-250V DC 100-250V AC / 50-60Hz 2.8 W / 3.1 VA | 40 | 30 | Ceiling/wall mounted emergency exit sign | 353x143x57 |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 8 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

GR range of emergency luminaires – Twinspots

Rated 220-240 V a.c, 50-60 Hz, Class II

BSI Test Report reference 8859302 Rev 1

| Model | Rating | IP | Duration | Assembly type | Dimensions (mm) |
|-------------------|-------------------------|------|-----------|-------------------------------------|-------------------|
| GRL-37/90 | 220-240 V a.c, 50-60 Hz | IP42 | 1.5 hours | Surface mounted emergency luminaire | 302 x 94 x 330 mm |
| GRL-37/180 | 220-240 V a.c, 50-60 Hz | IP42 | 3 hours | Surface mounted emergency luminaire | 302 x 94 x 330 mm |
| GRL-37/90/WP | 220-240 V a.c, 50-60 Hz | IP65 | 1.5 hours | Surface mounted emergency luminaire | 307 x 100 x 33 mm |
| GRL-37/180/WP | 220-240 V a.c, 50-60 Hz | IP65 | 3 hours | Surface mounted emergency luminaire | 307 x 100 x 33 mm |
| GRL-37/90/ADR | 220-240 V a.c, 50-60 Hz | IP42 | 1.5 hours | Surface mounted emergency luminaire | 302 x 94 x 330 mm |
| GRL-37/180/ADR | 220-240 V a.c, 50-60 Hz | IP42 | 3 hours | Surface mounted emergency luminaire | 302 x 94 x 330 mm |
| GRL-37/90/WP/ADR | 220-240 V a.c, 50-60 Hz | IP65 | 1.5 hours | Surface mounted emergency luminaire | 307 x 100 x 33 mm |
| GRL-37/180/WP/ADR | 220-240 V a.c, 50-60 Hz | IP65 | 3 hours | Surface mounted emergency luminaire | 307 x 100 x 33 mm |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 9 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

ZLD range of emergency luminaires for central battery system

Rated: Some luminaires are 55-250VDC/ 100-250V AC IP40

BSI Test Report reference 8856141 Rev 1

| Model | Rating | Light Source | IP | Assembly type |
|---------------------|-----------------------------------|--------------|------|--------------------------------|
| ZLD-34/24V/ADR/EM | 15-30V DC Class III 50/60Hz | LED | IP40 | Ceiling/wall mounted Exit sign |
| ZLD-28/24V/ADR/EM | 15-30V DC Class III 50/60Hz | LED | IP40 | Ceiling/wall mounted Exit sign |
| ZLD-34/CBS/24VDC/EM | 15-30V DC Class III 50/60Hz | LED | IP40 | Ceiling/wall mounted Exit sign |
| ZLD-28/CBS/24VDC/EM | 15-30V DC Class III 50/60Hz | LED | IP40 | Ceiling/wall mounted Exit sign |
| ZLD-34/CBS/EM | 15-30V DC Class I 50/60Hz | LED | IP40 | Ceiling/wall mounted Exit sign |
| ZLD-28/CBS/EM | 15-30V DC Class I 50/60Hz | LED | IP40 | Ceiling/wall mounted Exit sign |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 10 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015.

GR range of emergency luminaires for central battery system

Rated: Some luminaires are 90-250VDC/ 120-250V AC IP40

BSI Test Report reference 8856142 Rev 1

| Model | Rating | Light Source | IP | Assembly type |
|----------------|---|--------------|------|--|
| GR-281/24V/ADR | 15-30V DC Class III 50/60Hz | LED | IP40 | Ceiling/wall recess mounted emergency luminaire for central battery system |
| GR-280/24V/ADR | 15-30V DC Class III 50/60Hz | LED | IP40 | Ceiling/wall recess mounted emergency luminaire for central battery system |
| GR-281/24VDC | 15-30V DC Class III 50/60Hz | LED | IP40 | Ceiling/wall recess mounted emergency luminaire for central battery system |
| GR-280/24VDC | 15-30V DC Class III 50/60Hz | LED | IP40 | Ceiling/wall recess mounted emergency luminaire for central battery system |
| GR-281 | 90-250 V DC 120-250V AC Class II 50/60Hz | LED | IP40 | Ceiling/wall recess mounted emergency luminaire for central battery system |
| GR-280 | 90-250 V DC 120-250V AC Class II 50/60Hz | LED | IP40 | Ceiling/wall recess mounted emergency luminaire for central battery system |

First Issued: 2016-01-14

Latest Issue: 2019-09-18

Effective Date: 2019-09-18

Expiry Date: 2022-09-17

Page: 11 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.