



Product Service

Attestation of Conformity

E8A 003350 0005 Rev. 00

Holder of Certificate: **TECNOCNTROL S.R.L.**
 Via Miglioli 47
 20090 Segrate (MI)
 ITALY

Name of Object: **gas detection systems**

Model(s): TS282KM, TS282KG, TS282KI, TS282KB, TS282PM,
 TS282PG, TS282PI, TS282PB, TS282PX, TS282EA,
 TS282EA-H, TS282EC-S, TS282EC-H, TS282ES,
 TS282EH, TS282EHCN, TS282EHCL, TS282ECL,
 TS282EN, TS282EN2, TS282EO, TS282IC2, TS282IC2-H,
 TS282SFn, TS282SFn-H, TS282SFX, TS282SFX-H,
 TS282SIFn, TS282IFn-H, TS282IFX

Description of Object:

Rated voltage:	12 - 24 Vdc
Rated power:	2 W
Degree of protection against liquids:	IP65

Tested according to: EN 50270:2015
 EN 61000-6-4:2007/A1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: EMC1059668CA

Date, 2018-07-24 *(Giuseppe Mecchia)*
 (GIUSEPPE MECCHIA)

Page 1 of 1
 After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

